



Number	KIP-07949	Replaces	KIP-07632
Issue date	03-07-2025	Contract number	I0220
Due date	02-07-2035	Scope	(EU) 2016/426 (9 March 2016)
Report number	2002699/2	Module	B (Type testing)
PIN	0476CT2699		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the Central heating boilers, type(s):

City Class 24 C Nox
City Class 28 C Nox

Manufacturer

ITALTHERM S.p.A.
Via Salvo d'Acquisto
29010 Pontenure (PC) - Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2021+A1:2023, EN15502-2-2:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager
Maurizio Lorenzon



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Number	KIP-07949	Page	1 of 1
Issue date	03-07-2025	Scope	(EU) 2016/426 (9 March 2016)
Due date	02-07-2035	Module	B (Type testing)
Report number	2002699/2		
PIN	0476CT2699		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name: **ITALTHERM**

Types:

Model name	Appliance types	Heat Input (Hi)	
		CH Max – Min (kW)	DHW Max – Min (kW)
City Class 24 C Nox	B _{11BS}	26,5 – 10,0 ⁽¹⁾ 25,5 – 13,0 ⁽²⁾	26,5 – 10,0 ⁽¹⁾ 25,5 – 13,0 ⁽²⁾
City Class 28 C Nox		29,5 – 11,0 ⁽¹⁾ 28,5 – 14,0 ⁽²⁾	29,5 – 11,0 ⁽¹⁾ 28,5 – 14,0 ⁽²⁾

⁽¹⁾ heat input declared for the gas categories E, H, P

⁽²⁾ heat input declared for the gas categories E+

Countries:

AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GR, HR, HU, IE, IT, LT, LU, LV, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar
E	20
E+	20/25

Group	mbar
H	20;25

Group	mbar
P	37

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Remarks: --

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.